

Coast Guard, DOT

§ 95.05–10

Subpart 95.50—Hand Portable Fire Extinguishers and Semiportable Fire Extinguishing Systems, Arrangements and Details

- 95.50–1 Application.
- 95.50–5 Classification.
- 95.50–10 Location.
- 95.50–15 Spare charges.
- 95.50–20 Semiportable fire extinguishers.
- 95.50–90 Vessels contracted for prior to November 19, 1952.

Subpart 95.60—Fire Axes

- 95.60–1 Application.
- 95.60–5 Number required.
- 95.60–10 Location.

AUTHORITY: 46 U.S.C. 3306; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; 49 CFR 1.46.

SOURCE: CGFR 65–50, 30 FR 17001, Dec. 30, 1965, unless otherwise noted.

Subpart 95.01—Application

§ 95.01–1 General.

(a) The provisions of this part shall apply to all vessels except as specifically noted in this part.

§ 95.01–2 Incorporation by reference.

(a) Certain material is incorporated by reference into this part with the approval of the Director of the Federal Register in accordance with 5 U.S.C. 552(a). To enforce any edition other than that specified in paragraph (b) of this section, the Coast Guard must publish notice of change in the FEDERAL REGISTER and make the material available to the public. All approved material is on file at the Office of the Federal Register, 800 North Capitol Street, NW., suite 700, Washington, DC, and at the U.S. Coast Guard, Office of Design and Engineering Standards (G-MSE), 2100 Second Street SW., Washington, DC 20593–0001 and is available from the sources indicated in paragraph (b) of this section.

(b) The material approved for incorporation by reference in this part and the sections affected are:

American Society for Testing and Materials (ASTM)

100 Barr Harbor Drive, West Conshohocken, PA 19428–2959

ASTM F–1121, International Shore Connections for Marine Fire Applications, 1987—95.10–10

National Fire Protection Association (NFPA)

1 Batterymarch Park, Quincy, MA 02269–9101.
NFPA 13–1996, Standard for the Installation of Sprinkler Systems—95.30–1

[CGD 88–032, 56 FR 35825, July 29, 1991, as amended by CGD 95–072, 60 FR 50464, Sept. 29, 1995; CGD 96–041, 61 FR 50729, Sept. 27, 1996; CGD 97–057, 62 FR 51045, Sept. 30, 1997; CGD 95–028, 62 FR 51206, Sept. 30, 1997]

§ 95.01–5 Equipment installed but not required.

(a) Where fire detecting or extinguishing systems or equipment are not required, but are installed, the system or equipment and its installation shall meet the requirements of this part.

Subpart 95.05—Fire Detecting and Extinguishing Equipment, Where Required

§ 95.05–1 Fire detecting, manual alarm, and supervised patrol systems.

(a) Fire detecting, manual alarm, and supervised patrol systems are not required except in special cases; but if installed, the systems shall meet the applicable requirements of part 76 of subchapter H (Passenger Vessels) of this chapter.

(b) In each compartment containing explosives, and in adjacent cargo compartments, there shall be provided a smoke detecting or other suitable type fire detecting system.

(c) Enclosed spaces which are “specially suitable for vehicles” shall be fitted with an approved fire or smoke detecting system.

[CGFR 66–33, 31 FR 15285, Dec. 6, 1966]

§ 95.05–5 Fire main system.

(a) Fire pumps, hydrants, hose, and nozzles shall be installed on the following vessels:

(1) On all self-propelled vessels.

(2) On all barges with sleeping accommodations for more than 12 persons.

(b) The arrangements and details of the fire main system shall be as set forth in subpart 95.10.

§ 95.05–10 Fixed fire extinguishing systems.

(a) Approved fire extinguishing systems may be used or required in locations delineated in this section on the